

**GOVERNMENT COLLEGE FOR WOMEN (AUTONOMOUS)**

**KUMBAKONAM-612001**

*Affiliated to Bharathidasan University*

**DST-CURIE Sponsored Institution IV**

**Cycle of Accreditation**



☎ 0435 – 2401391

✉ [principal@gcw.ac.in](mailto:principal@gcw.ac.in)



## ENERGY AUDIT

**GOVERNMENT COLLEGE FOR WOMEN(AUTONOMOUS)**

**KUMBAKONAM – 612 001**

*Affiliated to Bharathidasan University*

**DST - CURIE Sponsored Institution**

**IV Cycle of Accreditation**



☎ 0435 – 2401391

✉ [principal@gcwk.ac.in](mailto:principal@gcwk.ac.in)



## **Energy Audit**

In an attempt to conserve energy and reduce power consumption, energy audit had been carried out in the campus. The Energy Audit focuses on the replacement of tube lights either by CFL or LED bulbs and the replacement of old CRT monitors by LCD monitors, depending on the allocation of resources from the Government of Tamil Nadu either for IT infrastructure or for upgradation of electrical infrastructure. The following table gives an assessment of how the process has been initiated in a phased manner in the last five years.


*P. Manjula*  
Junior Engineer PWD,  
Tech. Edn. Electrical Section  
Kumbakonam.



**ENERGY AUDIT IN THE CAMPUS**

**1. Replacement of Tube Lights by LED/CFL Bulbs**

LOCATION	DETAILS OF ENERGY CONSUMPTION	TUBE LIGHTS	REPLACED BY CFL	REPLACED BY LED	ENERGY SAVED
<b>IQAC Room</b>	Number of bulbs	6	12		<b>23.232 kW</b>
	Watt per bulb	40	9		
	Energy consumed by the bulbs	0.24 kW	0.108 kW		
	Energy consumed per month*	0.24x8x22 =42.24 kW	0.108x8x22 =19.008 kW		
<b>Principal Chamber</b>	Number of bulbs	11		11	<b>11.616 kW</b>
	Watt per bulb	36		30	
	Energy consumed by the bulbs	0.396 kW		0.33 kW	
	Energy consumed per month*	0.396x8x22 =69.696 kW		0.33x8x22 =58.08 kW	
<b>Administrative Block</b>	Number of bulbs	21		21	<b>36.96 kW</b>
	Watt per bulb	40		30	
	Energy consumed by the bulbs	0.84 kW		0.63 kW	
	Energy consumed per month*	0.84x8x22 =147.84 kW		0.63x8x22 =110.88 kW	
<b>Council Hall</b>	Number of bulbs	8		8	<b>8.448 kW</b>
	Watt per bulb	36		30	
	Energy consumed by the bulbs	0.288 kW		0.24 kW	
	Energy consumed per month*	0.288x8x22 =50.688 kW		0.24x8x22 =42.24 kW	
<b>COE Room</b>	Number of bulbs	11		11	<b>38.72 kW</b>
	Watt per bulb	40		20	
	Energy consumed by the bulbs	0.44 kW		0.22 kW	
	Energy consumed per month*	0.44x8x22 =77.44 kW		0.22x8x22 =38.72 kW	

  
 Junior Engineer PWD,  
 Tech. Edn. Electrical Section,  
 Kumbakonam.

# GOVERNMENT COLLEGE FOR WOMEN(AUTONOMOUS)

KUMBAKONAM - 612 001

Affiliated to Bharathidasan University

DST - CURIE Sponsored Institution

IV Cycle of Accreditation



Estd. 1963

☎ 0435 - 2401391

✉ principal@gwkw.ac.in



<b>Strong Room</b>	Number of bulbs	12		12	<b>33.79 kW</b>
	Watt per bulb	36		20	
	Energy consumed by the bulbs	0.432 kW		0.24 kW	
	Energy consumed per month*	$0.432 \times 8 \times 22 = 76.03 \text{ kW}$		$0.24 \times 8 \times 22 = 42.24 \text{ kW}$	
<b>Valuation Hall</b>	Number of bulbs	9		9	<b>25.344 kW</b>
	Watt per bulb	36		20	
	Energy consumed by the bulbs	0.324 kW		0.18 kW	
	Energy consumed per month*	$0.324 \times 8 \times 22 = 57.024 \text{ kW}$		$0.18 \times 8 \times 22 = 31.68 \text{ kW}$	
<b>Old seminar Hall</b>	Number of bulbs	15		15	<b>52.8 kW</b>
	Watt per bulb	40		20	
	Energy consumed by the bulbs	0.6 kW		0.3 kW	
	Energy consumed per month*	$0.6 \times 8 \times 22 = 105.6 \text{ kW}$		$0.3 \times 8 \times 22 = 52.8 \text{ kW}$	
<b>Data Structure Lab</b>	Number of bulbs	18		18	<b>12.672 kW</b>
	Watt per bulb	40		36	
	Energy consumed by the bulbs	0.72 kW		0.648 kW	
	Energy consumed per month*	$0.72 \times 8 \times 22 = 126.72 \text{ kW}$		$0.648 \times 8 \times 22 = 114.048 \text{ kW}$	
<b>Solar powered /Sensor based Street Lights</b>	Number of bulbs	4		4	<b>35.2 kW</b>
	Watt per bulb	40		0.5(multiple of LEDs)≈ 90 Watts solar panel	
	Energy consumed by the bulbs	0.16 kW		0.36 kW	

*P. Manjunath*  
 Junior Engineer PWD,  
 Tech. Edn. Electrical Section  
 Kumbakonam.

# GOVERNMENT COLLEGE FOR WOMEN(AUTONOMOUS)

KUMBAKONAM - 612 001

Affiliated to Bharathidasan University

DST - CURIE Sponsored Institution

IV Cycle of Accreditation



☎ 0435 - 2401391

✉ principal@gcw.ac.in



	Energy consumed per month*	28.16 kW		63.36 kW	
<b>Sensor based lights (COE Block)</b>	Number of bulbs	4		4	
	Watt per bulb	40		9	
	Energy consumed by the bulbs	0.16 kW		0.036 kW	
	Energy consumed per month *	$0.16 \times 8 \times 22 = 28.16 \text{ Kw}$		$0.036 \times 8 \times 22 = 6.336 \text{ Kw}$	<b>21.824 kW</b>
<b>D- CIF (DST-CURIE LAB)</b>	Number of bulbs	12		12	
	Watt per bulb	40		36	
	Energy consumed by the bulbs	0.48 kW		0.432 kW	
	Energy consumed per month *	$0.48 \times 8 \times 22 = 84.48 \text{ kW}$		$0.432 \times 8 \times 22 = 76.032 \text{ kW}$	<b>8.448 kW</b>
<b>Total Energy Saved = 309.054 kW</b>					

- Assuming that the college works for 8 hours per day and 22 working days per month.
- Replacement of Conventional lights with Energy Efficient LED lights has been done in a phased manner.

*P. Madhavan*  
Junior Engineer PWD,  
Tech. Edn. Electrical Section  
Kumbakonam

# GOVERNMENT COLLEGE FOR WOMEN(AUTONOMOUS)

KUMBAKONAM – 612 001

Affiliated to Bharathidasan University

DST - CURIE Sponsored Institution

IV Cycle of Accreditation



0435 – 2401391

principal@gcw.ac.in



## 2. Replacement of CRT Monitors by LCD Monitors

Monitor Screen size	Number of CRT Monitors	Number of LCD Monitors	Energy Consumption in CRT Monitors	Energy Consumption in LCD Monitors	ENERGY Saved
14"	70	70	360 WATT	200 WATT	<b>14.4 KW</b>
15"	14	14	360 WATT	200 WATT	
17"	06	06	360 WATT	200 WATT	
<b>TOTAL</b>	<b>90</b>	<b>90</b>	<b>32.4 KW</b>	<b>18 KW</b>	

*P. Manjunath*  
Junior Engineer PWD,  
Tech. Edn. Electrical Section  
Kumbakonam.